



**CONTRACTOR APPOINTMENT FOR TERMINAL BOOSTER PUMPS REPLACEMENT FOR A ONCE OFF PERIOD AT KING SHAKA INTERNATIONAL AIRPORT. Tender Ref KSIA7181/2023/RFP**

QUESTION	ANSWER
Is there a specific brand that is required	The tender rules and regulations do not allow brand specification
Demolition scope	The bidder is expected to scope and price for any demolition based the new equipment they will be supplying, and information gathered at the site inspection
Do pumps need to be replaced	Yes, whole pump system needs to be replaced
How many back up pumps	The system should have  1x duty pump, 1x standby and 2x back up
Is ACSA changing the entire Pipe work	No, the bidder will modify the pipework as needed for the new installation based on information gathered from the site inspection