

QUESTIONS AND ANSWERS during the briefing session and site meeting

QUESTION	ANSWER
Compulsory Briefing Session	
Will the Employer provide testing equipment for the onsite testing?	Yes, equipment will be provided by the employer
Can an excel spreadsheet be provided?	Yes
Will 4 ME PE be allowed to tender?	Yes, however will seek guidance and check with CIDB and ACSA
Non-compulsory Site Meeting	
What is the size of the sequence batch reactors?	Diameter=15300 mm and the height = 4000mm
Will there be any operation in the areas with additional submersible pumps?	No, only maintenance will be conducted as per maintenance frequency and corrective maintenance in case of failures
Can drawings be provided?	No, the drawings will be provided to the successful bidder

ADDENDUM

1. Provision for Chemicals has been changed from R450 000.00 to R1 500 000.00
2. Overall Provision has been changed from R645 000 to R1 695 000.00
3. Pricing Schedule 6 amended to include the monthly cost.

Pictures for the Airside Dump Facility





